

The Leamington United Mennonite Home and Apartments

**POLICY AND PROCEDURE**

<b>CATEGORY:</b> Administration	<b>SUBJECT:</b> Air Temperature	<b>SECTION:</b> A <b>POLICY:</b> 5
<b>DATE:</b> September, 2004	<b>Signature:</b> _____ ADMINISTRATOR	
<b>REVISION DATE:</b> February, 2011, June, 2015		

**AIR TEMPERATURE**

**POLICY:**

The Home shall maintain a minimum air temperature of 23° Celsius or 74° Fahrenheit.

**PROCEDURE:**

- All thermostats controlling the atmospheric temperature of the Home shall be set at a minimum 23° Celsius or 74° Fahrenheit.
- Air temperatures shall be monitored daily by the Maintenance Staff (Monday – Friday) and Housekeeping/Laundry Aides (Saturday – Sunday). These temperatures shall be recorded in the Air Temperature Chart kept in the Boiler room.
- If air temperatures fall below 23° Celsius or 74° Fahrenheit, the Administrator, or Designate, shall be notified immediately.

**Leamington Mennonite Home  
Air Temperature Log - LTC**

**Air Temperature: Minimum: 23C/74F**

**Location: 1st Floor - Long Term Care Facility**

<b>Date:</b>	<b>Time of Reading</b>	<b>Temperature</b>	<b>Initials</b>
1-Dec-19			
2-Dec-19			
3-Dec-19			
4-Dec-19			
5-Dec-19			
6-Dec-19			
7-Dec-19			
8-Dec-19			
9-Dec-19			
10-Dec-19			
11-Dec-19			
12-Dec-19			
13-Dec-19			
14-Dec-19			
15-Dec-19			
16-Dec-19			
17-Dec-19			
18-Dec-19			
19-Dec-19			
20-Dec-19			
21-Dec-19			
22-Dec-19			
23-Dec-19			
24-Dec-19			
25-Dec-19			
26-Dec-19			
27-Dec-19			
28-Dec-19			
29-Dec-19			
30-Dec-19			
31-Dec-19			